

# UKCA-Declaration of Conformity

Manufacturer: Emergency Lighting Products Limited

Address: Parbrook House  
Gillmans Industrial Estate  
Natts Lane, Billingshurst  
West Sussex, RH14 9EZ  
United Kingdom

Brand name: ELP

Product type: Amenity Max, LED Luminaire

Product designation: See attached list

The designated product(s) is (are) in conformity with the provisions of the following UK Legislations.

SI No. 1101: 2016 Electrical Equipment (Safety) Regulations 2016

SI No. 1091: 2016 Electromagnetic Compatibility Regulations 2016

SI No. 3032: 2012 The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

Further information regarding compliance with these Regulations is given in the annex which constitutes a part of this declaration.

Last two digits of the year in which the UKCA marking was affixed: 21

Place and date of signature: Billingshurst, 14<sup>th</sup> January 2021

Signature:



Name: Martin Afford – Technical Manager

This declaration of conformity is issued under the sole responsibility of the manufacturer. It certifies compliance with the indicated Regulations, but implies no warranty of properties

# UKCA-Declaration of Conformity – Annex

---

The conformity of the designated product(s) with the provisions of the UK regulation: Electrical Equipment (Safety) Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

<b>BS EN 60598-1:2015</b> <b>+ A1:2018</b>	Luminaires- Part 1: General requirements and tests
<b>BS EN 60598-2-22:2014</b> <b>+ A1:2020</b>	Luminaires- Part 2-22: Particular requirements- Luminaires for emergency luminaires
<b>BS EN 62493:2015</b>	Assessment of lighting equipment related to human exposure to electromagnetic fields
<b>BS EN 62471:2008</b>	Photobiological safety of lamps and lamp systems

---

The conformity of the designated product(s) with the provisions of the UK Regulation: Electromagnetic Compatibility Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

<b>BS EN 55015:2019</b> <b>+ A11:2020</b>	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
<b>BS EN 61000-3-2:2019</b>	Electromagnetic compatibility (EMC)- Part 3-2: Limits- Limits for harmonic currents emissions (equipment input current $\leq 16$ A per phase)
<b>BS EN 61000-3-3:2013</b> <b>+ A1:2019</b>	Electromagnetic compatibility (EMC)- Part 3-3: Limits- Limitation of voltage changes, voltage fluctuations and flicker in public low voltage supply systems, for equipment with rated current $\leq 16$ A per phase and not subjected to conditional connection.
<b>BS EN 61547:2009</b>	Equipment for general lighting purposes -EMC immunity requirements

---

# UKCA-Declaration of Conformity – Attached List

---

AMAX/STD/M3 Standard cover; Maintained emergency

AMAX/STD/P Standard cover; Mains only

AMAX/STD/M3D Standard cover; Maintained DALI/Self-Test emergency

OPTIONS: suffix

/MW Micro-Wave presence detector

/EYE (instead of STD) 'Eyelid' cover (instead of Standard)

/CBD (instead of STD) 'Crossblade' cover (instead of Standard)

/WH White body and cover