

# UKCA-Declaration of Conformity

---



Manufacturer: Emergency Lighting Products Limited

Address: Parbrook House  
Gillmans Industrial Estate  
Natts Lane, Billingshurst  
West Sussex, RH14 9EZ  
United Kingdom

Brand name: ELP

Product type: Mondos LED Exit Sign Luminaire

Product designation: See attached list

The designated product(s) is (are) in conformity with the provisions of the following UK Legislations.

SI 2016 No. 1101 Electrical Equipment (Safety) Regulations 2016

SI 2016 No. 1091 Electromagnetic Compatibility Regulations 2016

SI 2012 No. 3032 The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

Further information regarding compliance with these Regulations is given in the annex which constitutes a part of this declaration.

Last two digits of the year in which the UKCA marking was affixed: 24

Place and date of signature: Billingshurst, 13<sup>th</sup> November 2024

Signature: 

Name: Martin Afford – Technical Manager

This declaration of conformity is issued under the sole responsibility of the manufacturer. It certifies compliance with the indicated Regulations, but implies no warranty of properties

# UKCA-Declaration of Conformity – Annex

---

The conformity of the designated product(s) with the provisions of the UK regulation: Electrical Equipment (Safety) Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

<b>BS EN 60598-1:2015</b> <b>+ A1:2018</b>	Luminaires- Part 1: General requirements and tests
<b>BS EN 60598-2-22:2014</b> <b>+ A1:2020</b>	Luminaires- Part 2-22: Particular requirements- Luminaires for emergency luminaires
<b>BS EN 62493:2015</b>	Assessment of lighting equipment related to human exposure to electromagnetic fields
<b>BS EN 62471:2008</b>	Photobiological safety of lamps and lamp systems

---

The conformity of the designated product(s) with the provisions of the UK Regulation: Electromagnetic Compatibility Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

<b>BS EN 55015:2019</b> <b>+ A11:2020</b>	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
<b>BS EN 61000-3-2:2019</b> <b>+ A1:2021</b>	Electromagnetic compatibility (EMC)- Part 3-2: Limits- Limits for harmonic currents emissions (equipment input current $\leq 16$ A per phase)
<b>BS EN 61000-3-3:2013</b> <b>+ A2:2021</b>	Electromagnetic compatibility (EMC)- Part 3-3: Limits- Limitation of voltage changes, voltage fluctuations and flicker in public low voltage supply systems, for equipment with rated current $\leq 16$ A per phase and not subjected to conditional connection.
<b>BS EN 61547:2023</b>	Equipment for general lighting purposes -EMC immunity requirements

---

# UKCA-Declaration of Conformity – Attached List

---

MON/30/230  
MON/30/M3  
MON/30/230D  
MON/30/M3D  
MON/50/230  
MON/50/M3  
MON/50/230D  
MON/50/M3D

**OPTIONS:**

MON/SUSP/KIT Suspension Kit for use with both 30M and 50M options