## **UKCA-Declaration of Conformity**



Manufacturer: Emergency Lighting Products Limited

Address: Parbrook House

Gillmans Industrial Estate Natts Lane, Billingshurst West Sussex, RH14 9EZ United Kingdom

Brand name: ELP

Product type: Aviator, LED Luminaire

Product designation: AV/HO/NM3/LI, AV/HO/NM3/DA/LI, AV/HO/230 & AV/HO/230D

The designated product(s) is (are) in conformity with the provisions of the following UK Legislations.

SI 2016 No. 1101 Electrical Equipment (Safety) Regulations 2016

SI 2016 No. 1091 Electromagnetic Compatibility Regulations 2016

SI 2012 No. 3032 The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

Further information regarding compliance with these Regulations is given in the annex which constitutes a part of this declaration.

Last two digits of the year in which the UKCA marking was affixed: 24 Place and date of signature: Billingshurst, 7<sup>th</sup> October 2024

Signature:

Name: Martin Afford – Technical Manager

This declaration of conformity is issued under the sole responsibility of the manufacturer. It certifies compliance with the indicated Regulations, but implies no warranty of properties

## **UKCA-Declaration of Conformity – Annex**

The conformity of the designated product(s) with the provisions of the UK regulation: Electrical Equipment (Safety) Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

BS EN 60598-1:2015

Luminaires- Part 1: General requirements and tests

+ A11:2022

BS EN 60598-2-22:2022 Luminaires- Part 2-22: Particular requirements- Luminaires for emergency

**luminaires** 

BS EN 62493:2015

Assessment of lighting equipment related to human exposure to

+A1:2022

electromagnetic fields

The conformity of the designated product(s) with the provisions of the UK Regulation: Electromagnetic Compatibility Regulations 2016, is given by the compliance with the following British Standard(s) or other specifications. If not elsewhere/otherwise indicated the edition/amendment as referenced below applies.

BS EN 55015:2019

Limits and methods of measurement of radio disturbance characteristics of

+ A11:2020 electrical lighting and similar equipment

BS EN 61000-3-2:2019 Electromagnetic compatibility (EMC)- Part 3-2: Limits- Limits for harmonic + A1:2021

currents emissions (equipment input current ≤ 16 A per phase)

+ A2:2021

BS EN 61000-3-3:2013 Electromagnetic compatibility (EMC)- Part 3-3: Limits- Limitation of voltage changes, voltage fluctuations and flicker in public low voltage supply systems,

for equipment with rated current ≤ 16 A per phase and not subjected to

conditional connection.

BS EN 61547:2023 Equipment for general lighting purposes -EMC immunity requirements